



3348 Route 208, Campbell Hall, NY 10916

Phone: 845-496-1600 Fax: 845-496-1398

12960 Commerce Lake Drive, A14, Fort Myers, FL 33913

42 Day Farm Road, West Stockbridge, MA 01266

1813 State Route 7, Harpursville, NY 13787

877 US-4, Schuylerville, NY 12871

Client:	Aden Aggregates	Project:	Grasso Quarry QC 2025
Item:	Select Structural Fill	Project Number:	250005
Source:	Grasso	Lab Number:	25-0221A
Date Sampled:	3/6/2025	Sampled By:	Client
Date Tested:	3/7/2025	Tested By:	Sean Curry

GRADATION (SIEVE ANALYSIS) OF SOIL OR AGGREGATE
Test Method(s): ASTM D422, C136, C117; AASHTO T88, T27, T11

Lab Number	Sample Type	Sampling Location	Specification
25-0221A	Select Structural Fill	Stockpile	

Sieve Size		% Retained	% Passing	Spec. % Pass
mm	Inches			
100.0 mm	4"	0.0	100	100
75.0 mm	3"	0.0	100	
63.0 mm	2 1/2"	0.0	100	
50.0 mm	2"	0.0	100	
37.5 mm	1 1/2"	0.0	100	
25.0 mm	1"	1.9	98	
19.0 mm	3/4"	8.2	90	
12.5 mm	1/2"	20.7	69	
6.3 mm	1/4"	27.7	42	
4.75 mm	#4	7.4	34	
2.00 mm	#10	14.4	20	
0.850 mm	#20	6.5	13	
0.600 mm	#30	1.4	12	
0.425 mm	#40	1.0	11	0-70
0.150 mm	#100	2.4	8	
0.075 mm	#200	1.3	7.1	0-15
Pan		7.1		

Comments: **Test results comply with specification**
 Minus #200 by wash-sieve method.

Report Reviewed By:

This report shall not be reproduced, except in full, without written permission from Advance Testing Company, Inc.
 The results in this report relate only to the items inspected or tested.

PDF