## Advance Testing

## **3348 Route 208, Campbell Hall, NY 10916 Phone: 845-496-1600 Fax: 845-496-1398** 12960 Commerce Lake Drive, A14, Fort Myers, FL 33913 42 Day Farm Road, West Stockbridge, MA 01266 1813 State Route 7, Harpursville, NY 13787 877 US-4 Schuylerville NY 12871

	877 03-4, Schuylervine, NY 12871			
Client:	Aden Aggregates	Project:	2024 Quality Control	
Item:	Biosoil	Project Number:	240511	
Source:	Riffka	Lab Number:	24-0790	
Date Sampled:	7/19/2024	Sampled By:	Client	
Date Tested:	7/22/2024	Tested By:	Brandon Diaz	

## GRADATION (SIEVE ANALYSIS) OF SOIL OR AGGREGATE Test Method(s): ASTM D422, C136, C117; AASHTO T88, T27, T11

Lab Number	Sample Type	Sampling Location	Specification	
24-0790	Biosoil	Stockpile	No Specification	

Sieve Size		%	%	Spec. %
mm	Inches	Retained	Passing	Pass
100.0 mm	4"	0.0	100	
75.0 mm	3"	0.0	100	
63.0 mm	2 1/2"	0.0	100	
50.0 mm	2"	0.0	100	
37.5 mm	1 1/2"	0.0	100	
25.0 mm	1"	0.0	100	
19.0 mm	3/4"	0.0	100	
12.5 mm	1/2"	0.0	100	
6.3 mm	1/4"	26.5	74	
4.75 mm	#4	2.9	71	
2.00 mm	#10	11.4	59	
0.850 mm	#20	11.6	48	
0.600 mm	#30	5.6	42	
0.425 mm	#40	5.2	37	
0.150 mm	#100	20.1	17	
0.075 mm	#200	9.4	7.3	
Pan		7.3		

Comments:

Minus #200 by wash-sieve method.

Kodriguez

Report Reviewed By:

This report shall not be reproduced, except in full, without written permission from Advance Testing Company, Inc. The results in this report relate only to the items inspected or tested. PDF