



3348 Route 208, Campbell Hall, NY 10916  
 Phone: 845-496-1600 Fax: 845-496-1398  
 12960 Commerce Lake Drive, A14, Fort Myers, FL 33913  
 42 Day Farm Road, West Stockbridge, MA 01266  
 1813 State Route 7, Harpursville, NY 13787  
 877 US-4, Schuylerville, NY 12871

<b>Client:</b>	Aden Aggregates	<b>Project:</b>	2024 Quality Control
<b>Item:</b>	3/4" Stone	<b>Project Number:</b>	240511
<b>Source:</b>	Grasso Quarry	<b>Lab Number:</b>	24-0507B
<b>Date Sampled:</b>	5/15/2024	<b>Sampled By:</b>	Client
<b>Date Tested:</b>	5/22/2024	<b>Tested By:</b>	Meghan Field

<b>GRADATION (SIEVE ANALYSIS) OF SOIL OR AGGREGATE</b>
Test Method(s): ASTM D422, C136, C117; AASHTO T88, T27, T11

Lab Number	Sample Type	Sampling Location	Specification
24-0507B	3/4" Stone	Stockpile	NYSDOT 703-02 #2 Stone

Sieve Size		% Retained	% Passing	Spec. % Pass
mm	Inches			
50.0 mm	2"	0.0	100	
37.5 mm	1 1/2"	0.0	100	100
25.0 mm	1"	4.4	96	90-100
19.0 mm	3/4"	28.2	67	
12.5 mm	1/2"	57.8	10	0-15
9.5 mm	3/8"	7.1	3	
6.3 mm	1/4"	0.8	2	
4.75 mm	#4	0.4	1	
3.18 mm	1/8"	0.1	1	
2.36 mm	#8	0.1	1	
Pan		1.1		

Comments: Test results comply with specification

*Emily J. Rodriguez*

Report Reviewed By:

This report shall not be reproduced, except in full, without written permission from Advance Testing Company, Inc.  
 The results in this report relate only to the items inspected or tested.